

**WASHINGTON COUNTY ENVIRONMENTAL SERVICES  
LINCOLN TRAIL DISTRICT HEALTH DEPARTMENT  
PRELIMINARY SITE EVALUATION 902 KAR 10:080/902 KAR 10:085**

**SUBDIVISION:** Shirley Cambron Preliminary

**LOCATION:** LOTS 5, 9 and 10. Botland Rd. Springfield KY 40069.

**DATE:** April 17, 2023

**OVERALL DESCRIPTION:** Lots 5 and 10 were fairly level lots, 9 was gently rolling. All lots are covered in grass.

**Lots deemed feasible for conventional or modified gravel and pipe or chamber systems:** Lots 5, 9, and 10.

**Lots requiring lagoon systems or fill and wait:** None.

**Lots unapproved:** None.

**Preliminary Findings:** Lots 5, 9, and 10 were looked at as possible building tracts, all less than 5 acres in size. One pit was dug on each lot. Lots have a 30' general utility easement. Lot 9 has grass drainageways. Lot 10 has an existing cistern on property and possible waterline. All listed items are considered setbacks for septic systems. Results are as follows:

**Lot 5: Silt loam to silty clay loam into silty clay. Claypan @ 38". Mottles @ 36".**

**Lot 9: Silt loam to silty clay loam into silty clay. Claypan @ 36". Mottles @ 26.**

**Possible curtain drains depending on location.**

**Lot 10: Silt loam to silty clay loam. No restriction.**

**\*\*Each lot will require an individual site evaluation and must stand on its own merit prior to a permit being issued for system installation.**

**Alexis Willett, RS  
Lincoln Trail District Health Department**