

**MARION COUNTY ENVIRONMENTAL SERVICES
LINCOLN TRAIL DISTRICT HEALTH DEPARTMENT
PRELIMINARY SITE EVALUATION 902 KAR 10:080/902 KAR 10:085**

SUBDIVISION: Lagoon Family Farms LLC Preliminary

LOCATION: LOTS 4, 6, 7, and 8- St. Joe Rd. Campbellsville, KY 42718

DATE: May 30, 2023

OVERALL DESCRIPTION: Lots 6, 7, and 8 are relatively level, crop covered tracts. Lot 4 is grass covered and gently rolling.

Lots deemed feasible for conventional or modified gravel and pipe or chamber systems:

Lots 4, 6, 7, and 8

Lots requiring lagoon systems or fill and wait: None.

Lots unapproved: None.

Preliminary Findings: Lots 4, 6, 7, and 8 were looked at as possible building tracts, all less than 5 acres in size. One hole was dug on each lot. Results are as follows:

Lot 4: Silt loam to silty clay loam. Mottling at 12". Fragipan @ 22". Water in pit. Curtain drain needed.

Lot 6: Silt loam to silty clay loam. Mottling at 12". Fragipan @ 22". Curtain drain needed.

Lot 7: Silt loam to silty clay loam. Mottling at 12". Fragipan @ 22". Curtain drain needed.

Lot 8: Silt loam to silty clay loam. Mottling at 18". Fragipan @ 23". Curtain drain needed.

****Each lot will require an individual site evaluation and must stand on its own merit prior to a permit being issued for system installation.**

**Alexis Willett, RS
Lincoln Trail District Health Department**